

# Probes installation kit

Cod. 3988



## Description

This kit allows the installation of the Minicell 15 and SS510 conductivity cells, and make the replacement or maintenance cleaning operations very simple.

The installation is possible on both the suction side and pressure side of the circulation pump; it is necessary to comply with the max. working pressure of the probe.

The s.s. pipes 8x10 mm. must be welded on the pump's pipe, and the 45° input side should result positioned in the center of the diameter, as shown in the drawing.

The s.s. plug 1/4 can be removed for cleaning operations to be carried out by the special brush supplied.

## Installation kit Components

## Code

- |  |      |
|--|------|
| 1) s.s. elbow fitting 1/4" and compression ring    | 0772 |
| 2) s.s. straight fitting 1/4" and compression ring | 1279 |
| 3) s.s. nipple 1/4" x 18 mm                        | 0485 |
| 4) s.s. "T" female 1/4"                            | 0854 |
| 5) ws.s. plug male 1/4"                            | 0735 |
| 6) s.s. pipe 8x10 - 100 mm.                        | 0989 |
| 7) s.s. pipe 8x10 - 120 mm.                        | 0958 |

